

- O Stormwater Infiltration Areas shall not be sited above the sewer main/easement or such that the sewer main is within the infiltration zone and/or resulting effects of groundwater mounding.
- o Prior to construction a pipe line evaluation shall be performed along the 14/18" sewer main. Upon completion of construction, a post-construction evaluation of the sewer main shall be performed. Any damaged and/or disturbed pipe shall be repaired/replaced.